

**CORRIGENDUM - I**

**TENDER NO WTL/CT/BM/17-18/040 dated 15.02.2018**

<b>Section No</b>	<b>Clause No.</b>	<b>Page No</b>	<b>Category</b>	<b>Specification</b>	<b>To be Read As</b>
Section-J	1.8	30	Technical specification with compliance statement	Minimum Events Log Storage Capacity:50000	Minimum Events Log Storage capacity: 90000
	1.9	30	Communication	LAN , RS 485 wiegand ( Customizable format up to 256 bits) for connecting to access controller.	LAN, RS 485, Weigand 26 bit/ 34 bit may be added for better clarity, which need to be supplied now.
	1.20	31	Standard	CE,FCC,RoHS Compliant	CE,FCC,RoHS Compliant or STQC Compliant
	3	31	Standard	Shall conform to CE, UL,EN Standards	Shall conform to CE, UL,EN Standards or Indian Manufacturer confirming the relative similar equivalent Standard
	3	32	General Features	The AC provided shall support multiple, but not limited to the following card formats: a. Wiegand 26 Bit b. Wiegand 35 Bit (HID Corp 1000) c. Wiegand 37 Bit (HID iClass) d. Mifare 32 Bit CSN	The AC provided shall support multiple, but not limited to the following card formats: a. 26 bit and 34 bit b. Wiegand 35 Bit (HID Corp 1000) c. Wiegand 37 Bit (HID iClass) d. Mifare 32 Bit CSN
Section-A		7	Existing System Architecture of Time Attendance Monitoring System		Add Clause: "Current system architecture is preferred for better time attendance punch data protection."
Section-J(Annexure-IV)		35	Technical specification with compliance statement		Remove clause: "Support "Global Anti-pass back" upon availability of host server.N PERSON ACCESS: The access control management must provide the possibility to allow access to an entrance/door only when at least two authorized cardholder's swipe their badges. The number of cardholders for that kind of access check in front of an entrance shall not be limited by the system."