

WEBEL TECHNOLOGY LIMITED

CORRIGENDUM – II

TENDER NO. WTL/HC/UPS/17-18/042 DATED 20.02.2018

Sl. No.	Section	Clause No.	Page No.	Present Entry	Replace With
1	I	05	25	Backup Time-120 Minutes	Backup Time 120 Minutes (VAH - 4680)
2	I	06	25	Battery Type- Maintenance-free sealed Lead- Acid battery with suspended electrolyte: leak proof	Battery Type- Maintenance- free sealed Lead- Acid battery with suspended electrolyte: leak proof (Make: Exide/Quanta/Amaron)
3	I	05	23	Backup Time-60 Minutes	Backup Time 60 Minutes (VAH - 816)
4	I	06	23	Battery Type- Maintenance-free sealed Lead- Acid battery with suspended electrolyte: leak proof	Battery Type- Maintenance- free sealed Lead- Acid battery with suspended electrolyte: leak proof (Make : Exide/Quanta/Amaron)
5	I	06	22	Battery Type- Maintenance-free sealed Lead- Acid battery with suspended electrolyte: leak proof	Battery Type- Maintenance- free sealed Lead- Acid battery with suspended electrolyte: leakproof (Make : Exide/Quanto/Amaron)
6	I	03	25	230+/- 5% with AVR (Automatic Voltage Regulation), 50 hz+/- synchronized with Input Power Frequency	230+/- 5% , 50 hz+/- synchronized with Input Power Frequency
7	All the three items in Bill of Material (Section – H) must be quoted of same OEM.				
8	OEM must have single order of 3000 UPS installation in West Bengal. Order copy to be submitted.				
9	OEM/ SI Service Centre details will be cross verified and subject to the clause of blacklisting if not in conformity.				
10	Date and time of Bid Submission has been extended up to 23 rd March 2018 at 15.00 hrs.				
11	Date and time of Bid Opening has been extended up to 26 th March 2018 at 12.00 hrs.				
12	Date and time of EMD & Tender Fee submission has been extended up to 26 th March 2018 at 11.00 hrs.				