

Corrigendum –VI

Tender No. WTL/PAR/SDC/17-18/030, Dated 27.11.2017, Version 2

Sl.	Section	Clause No.	Vol. and Page No.	Original Clause/Query/Request	Revised Clause/Amendment
1.	Section -D	Clause 13 : CONTRACT EXECUTION	72	On receipt of the Letter of Award the contractor should submit a Performance Bank Guarantee (PBG) equivalent to 10% of the total contract value within three weeks from the date of receipt of Letter of Award/Order. The PBG should be valid for six month more than the warranty period. All delivery of the material will have to be completed within 45 days from the date of acceptance of contract and the contractor has to ensure all activities leading to the commissioning of the contract to be completed within 75 days from the date of award. Subsequent to the award of contract, the contractor will have to arrange for the requisite material as per BOM.	Clause changed as – On receipt of the Letter of Award the contractor should submit a Performance Bank Guarantee (PBG) equivalent to 10% of the total contract value within three weeks from the date of receipt of Letter of Award/Order. The PBG should be valid for six month more than the warranty period. All delivery of the material and installation, integration needs to be completed within stipulated timeline mentioned in “Clause 2.2.Schedule- II: Operation and Maintenance Phase, sub-clause - 3. Estimated Timelines”
2.	Section -D	14. TIM E SCHEDULE FOR DELIVERY & INSTALLA		The total delivery, installation & commissioning will have to be completed within 6-8 weeks from the date of Order.	The total delivery, installation & commissioning will have to be completed within stipulated timeline mentioned in “Clause 2.2. Schedule- II: Operation and Maintenance Phase, sub-clause - 3. Estimated Timelines”

Sl.	Section	Clause No.	Vol. and Page No.	Original Clause/Query/Request	Revised Clause/Amendment
		TION			
3.	SECTION – H	1.8 Data Center Infrastructure Management Sr. No. 12	209	The graphical floor plan of the configured data center layout should include overlays showcasing capture index (CI), plenum pressure, plenum velocities, and 3D rendering of the temperature map, including airflow and temperature thresholds. As the design takes place, client will get a qualified estimation of the effect of changes in supply temperature, airflow, and number of cooling units and room-based cooling parameters. The data is expected to be simulated on the basis of plate rating of various cooling devices, racks, perforated tiles, grilles etc.	Clause reinstated
4.	1.4. UPS: Non-Critical Load	Clause 33	195	Mandatory Sales & support Centre of OEM in Kolkata for last 5 years: OEM of UPS must have Sales & Support Centre in Kolkata for last 5 years and credential for supply of at least 100 units of similar UPS specs (or higher specs) in West Bengal for last 5 years. Credential of OEM for deployment of UPS of same specs or higher specs in National Data Centre of NIC or SDC or any other national Data Centre in India.	Clause changed as – Mandatory Sales & support Centre of OEM in Kolkata for last 5 years: OEM of UPS must have Sales & Support Centre in Kolkata for last 5 years. Credential of OEM for deployment of UPS of same specs or higher specs in National Data Centre of NIC or SDC or any other national Data Centre in India.
5.	Corrigendum - V	Sl. No. 14	5	The storage system should support remote replication for both file and block. For optimal usage of bandwidth and to reduce operating expenses remote replication should provide “Data De-duplication and Compression”. Any additional hardware or software required to achieve the same should be provided along with replication solution. For OEMs not providing data deduplication, remote replication should provide Compression.	Clause changed as – The storage system should support remote replication for both file and block. After data is replicated at remote storage, data should be stored with “Data De-duplication and Compression”. Any additional hardware or software required to achieve the same should be provided along with replication solution. For OEMs not supporting data deduplication, data at remote storage should be stored with Compression only.

Sl.	Section	Clause No.	Vol. and Page No.	Original Clause/Query/Request	Revised Clause/Amendment
6.				Date & Time of Bid Submission has been extended upto 16.01.2018 at 15:00 hrs	
7.				Date & Time of Bid opening has been extended upto 18.01.2018 at 15:00 hrs	
8.				Last Date & time of submission of original Demand Draft/Pay Order/Bank Guarantee for cost of Earnest Money Deposit (Off line) extended upto 16.01.2018 at 14:00 hrs.	
9.				Last Date & time of submission of original Demand Draft/Pay Order for cost of Tender Documents (Off line) have been extended upto 16.01.2018 at 14:00 hrs	
10.				Bid Submission start date & time extended upto 08.01.2018 at 14:00 hrs	